



# AC ENGINEERING ENTERPRISES, LLC

120 Aliso Drive, SE Albuquerque, NM 87108 Ph:(505) 842-5787 Fax:(505) 842-5797

May 04, 2016

Leopoldo (Polo) Pineda, Jr.  
City of Socorro (Chief Procurement Officer)  
Post Office Drawer K,  
Socorro, NM 87801  
PH: 575-835-0240

**RE: SOCORRO RODEO ARENA – SOCORRO, NM**

Dear Leopoldo,

The following shall be included in addendum #3:

**SOCORRO RODEO ARENA – ADDENDUM #3**  
**Electrical Addendum**

**DRAWINGS:**

**SHEET ES-101 (RODEO ARENA LIGHTING-NEW WORK PLAN):**

1. **CLARIFICATION:** FOR CLARIFICATION THE NOTE NUMBER 7, FOR THE LIGHTING CONTACTOR CABINET WILL BE LOCATED AT BELOW PANEL “RA” LOCATION. SEE THE POWER RISER DIAGRAM.
2. **REMOVE:** REMOVE NOTE #9, THE LIGHT FIXTURE AND RECEPTACLE IN THE ANNOUNCER BOOTH.
3. **REVISE:** REVISE THE NOTE NUMBER 1 & 2, FOR MOUNTING HANGER BRACKET TO BE TWO (2) # IBAC-120.
4. **CLARIFICATION:** FOR CLARIFICATION THE NOTE NUMBER 7, FOR THE LIGHTING CONTACTOR CONTROL CABINET WILL BE LOCATED AT BELOW PANEL “RA” LOCATION. SEE THE POWER RISER DIAGRAM.

**SHEET ES-102 (RODEO ARENA POWER-NEW WORK PLAN):**

1. **CHANGE:** CHANGE THE NOTE NUMBER 7, TO READ “NEW LIGHTING CONTROL CABINET WITH ELECTRICALLY HELD LIGHTING CONTACTORS FOR CONTROL OF RODEO BLEACHER SEATING LIGHTING, ARENA LIGHTING, CONCESSION & PEN LIGHTING AND THE BIG ASS FANS. PROVIDE (5) SWITCHES FOR CONTROL OF INDIVIDUAL CONTACTORS. SEE KEYNOTE 7 ON ES101 & KEYNOTE 15”.
2. **REMOVE:** REMOVE NOTES #17, & #18 FROM THE PLAN DRAWING. REMOVE CIRCUITS TO THE ANNOUNCERS STAND/BOOTH.
3. **ADD:** ADD NOTE #16 TO READ “ALL DUPLEX AND QUAD RECEPTACLES THAT WILL BE INSTALLED AT THE PERIMETER OF THE ARENA OR ELSEWHERE THAT ARE EXPOSED TO THE ELEMENTS, SHALL BE GFI/WEATHERPROOF TYPE RECEPTACLES WITH HEAVY DUTY METAL IN-USE COVERS”
4. **REVISE:** REVISE THE PANEL SCHEDULE “2RA” TO BE 120/208V-3PH, 4W. PROVIDE A 225A, MAIN CIRCUIT BREAKER IN PANEL AND 10 KA MINIMUM INTERRUPTING CAPACITY.

**END OF ADDENDUM #1 ITEMS**